

Requirement N1 – Critical Locations

1.1 The following locations may be considered “critical” in terms of safety;

between finished floor level and **800mm** above that level in internal walls and partition, (see Diagram 1).

between finished floor level and **1500mm** above that level in a door or in a side panel, close to either edge of the door (300mm) in any pane (see Diagram 1).

